

MISTER CRN CONSULTING INC.
PO BOX 488
MONTAGUE PE C0A 1R0

Date: February 3, 2021
Account #: 59720
Journal #: 77203

Attn: MILLER

Re: Application for Design Registration

The design, as detailed in your, 2776, for a Fitting is accepted for registration as follows:

Registered To: AALBERTS INTEGRATED PIPING **CRN:** 0D2480.71
SYSTEMS APAC INC.

Drawing #: #650N

Drawing Revision: 9

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Reviewer's Notes:

As required by CSA B51 4.2.1, this registration expires on 11-Dec-2030. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void. Any additional conditions of registration stated in New Brunswick CRN# 0D2480.7Rev1 registration shall apply to BC registration.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

Janina Mihailescu

janina.mihailescu@technicalsaftybc.ca
Design Administration

cc:

CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category D - Expansion Joints)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
650N Expansion Joint	2, 2½, 3, 4, 6	175	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	165