

January 22, 2021

Attention: Miller West
MISTER CRN CONSULTING INC
BOX 488
MONTAGUE, PE C0A 1R0

The design submission, tracking number 2021-00106, originally received on January 07, 2021 was surveyed and accepted for registration as follows:

CRN : 0D02480.72 **Accepted on:** January 22, 2021
Reg Type: RENEWAL **Expiry Date:** December 11, 2030
Drawing No. : DWG. NO. 165 Rev 9
Fitting type: EXPANSION JOINT, MODEL 650N, SIZES 2", 2.5", 3", 4", 6"
Design registered in the name of : AALBERTS INTEGRATED PIPING SYSTEMS APAC INC

The registration is conditional on your compliance with the following notes:

- Please note that this letter supersedes the letter issued on Jan 22, 2021. The omitted 4" size is added in the acceptance letter.
- The scope of this registration is the CRN renewal and the name of manufacturer is changed from Shurjoint to Aalberts Integrated Piping Systems APAC Inc.
As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction is ASME B31.3.
- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.
- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3382 or fax (780) 437-7787 or e-mail Stojanovic@absa.ca.

Sincerely,



STOJANOVIC, STEVAN, P. Eng.
DOP Cert. No. D00008849

CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category D - Expansion Joints)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
650N Expansion Joint	2, 2½, 3, 4, 6	175	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	165