



Technical Standards and Safety Authority  
 345 Carlingview Drive  
 Toronto, Ontario M9W 6N9  
 www.tssa.org



## STATUTORY DECLARATION Registration of Fittings

I, CHIUI, YING - CHUAN, Plant Manager  
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of Aalberts integrated piping systems APAC Inc.  
(Name of Manufacturer)

Located at No. 295, Sec. 3, Wandan Road, Wandan Township, Pingtung, Taiwan 886-8-752-5877 886-8-753-0227  
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B31.3  
(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with \_\_\_\_\_ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001:2015 which has been verified by the following authority, LRQA certificate No. ISO 9001 - 0068440.

The items covered by this declaration, for which I seek registration, are category D type fittings. In support of this application, the following information and/or test data are attached as follows:

Renew OD2480.75. See document "CRN Registration" dated Oct. 30, 2020, drawings & proof test records.  
(drawings, calculations, test reports, etc.)

Declared before me at Kaohsiung in the Republic of China

the 20th day of November AD 2020.

Commissioner for Oaths:

HUANG, CHI-RONG  
(Printed name)

Huang, Chi-rong  
(Signature)

CHIUI, YING CHUAN  
(Signature of Declarer)

### FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category D.

CRN: OD2480.75R1  
 Registered by: Charley Dong See attached "Part of CRN" For the scope  
 Dated: Mar. 30, 2021

NOTE: This registration expires on: Dec. 11.2030

Technical Standards and Safety Authority  
 Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.: OD2480.75R1

Signed: Charley Dong

Date: March 30, 2021

*\*Information provided in this application is releasable under the Freedom of Information and Privacy Protection Act and may be disclosed upon request.*

# CRN Registration

Oct. 30, 2020

Shurjoint Grooved Components are to be registered (Category D - Expansion Joints)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
650N Expansion Joint	2, 2½, 3, 4, 6	175	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	165