



HLXS7.EX15439 - Butterfly Valves Certified for Canada

Butterfly Valves Certified for Canada

Aalberts integrated piping systems APAC Inc
 295 SEC 3 WANDAN RD
 WANDAN TOWNSHIP
 PINGTUNG HSIEN, 913 Taiwan

EX15439

Model	Size, NPS	Body Type	Pressure Rating, Bar	Indicator Post	Supervisory Switch*
Butterfly valve					
SJ-300FV	2, 2.5 (76.1 mm), 2.5, 3, 4, 5, 5 (139.7 mm), 6, 6 (165.1 mm)	Groove	20	—	I, O
	8, 8 (216.3 mm), 10, 10 (267.4 mm)				
	12, 12 (318.4 mm)				
SJ-300FV-A	10,10(267.4mm), 12,12(318.4mm)	Groove	20	—	I, O

* I = Indoor installation; O = Outdoor installation

Trademark and/or Tradename: "SHURJOINT", **SHURJOINT**,  SHURJOINT

Last Updated on 2022-01-14

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"