

This Product MasterSpec Section is licensed by ARCOM to Apollo Flow Controls, Conbraco Industries, Inc ("Licensee").

This Product MasterSpec Section modifies the original MasterSpec text and does not include the full content of the original MasterSpec Section.

Revisions made to the original MasterSpec text are made solely by the Licensee and are not endorsed by, or representative of the opinions of, ARCOM or The American Institute of Architects (AIA). Neither AIA nor ARCOM are liable in any way for such revisions or for the use of this Product MasterSpec Section by any end user. A qualified design professional should review and edit the document to suit project requirements.

For more information about Apollo Valves, contact Conbraco Industries, Inc., P.O. Box 247, Matthews, NC 28105; Phone: (704) 847-6000; Fax: (704) 841-6020; Website: www.apollovalves.com; Email: TechSupport@Conbraco.com.

For more information about Apollo-Shurjoint, contact Apollo-Shurjoint, 1380 Beverage Drive, Suite P, Stone Mountain, GA 30083, USA; Phone: (770) 817-0444; Fax: (770) 817-0443; Website: www.Shurjoint.com.

For information about MasterSpec, contact ARCOM at (800) 424-5080 or visit www.MasterSpec.com.

SECTION 220523.13 - BUTTERFLY VALVES FOR PLUMBING PIPING

TIPS:

To view non-printing **Editor's Notes** that provide guidance for editing, click on MasterWorks/Single-File Formatting/Toggle/Editor's Notes.

To read **detailed research, technical information about products and materials, and coordination checklists**, click on MasterWorks/Supporting Information.

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Iron, single-flange butterfly valves.
 - 2. Iron, grooved-end butterfly valves.
 - 3. Chainwheels.

1.3 DEFINITIONS

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene-diene terpolymer rubber.
- C. LF: Lead Free.
- D. MSS: Manufacturer's Standardization Society.
- E. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- F. NSF: National Sanitation Foundation.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.
 - 1. Certification that products comply with [NSF 61] [and] [NSF 372].

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
 - 1. Protect internal parts against rust and corrosion.
 - 2. Protect threads, flange faces, grooves, and weld ends.
 - 3. Set butterfly valves closed or slightly open.
- B. Use the following precautions during storage:
 - 1. Maintain valve end protection.
 - 2. Store valves indoors and maintain at higher-than-ambient-dew-point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

1.6 WARRANTY

- A. Manufacturer's Special Warranty on Domestic Products: Conbraco Industries, Inc. warrants products to be free of defects in workmanship or material for a period of five years. This warranty applies to Apollo brand products with "Made in the USA" markings only. Conbraco will correct such defects by suitable repair or replacement at Conbraco's discretion.
- B. Manufacturer's Special Warranty on International Products: APOLLO INTERNATIONAL products will be free of defects in workmanship or material for a period of two years. Conbraco will correct such defects by suitable repair or replacement at Conbraco's discretion.

- C. Manufacturer's Special Warranty on Apollo-Shurjoint Products warrants products to free of defects in workmanship or material for a period of ten years. This Limited Warranty applies to manufacturing defects only and does not cover severe service/temperature applications or wear parts.

PART 2 - PRODUCTS

2.1 GENERAL REQUIREMENTS FOR VALVES

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
1. ASME B16.1 for flanges on iron valves.
 2. ASME B16.5 for flanges on steel valves.
 3. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
 4. ASME B31.9 for building service piping valves.
- C. AWWA Compliance: Comply with AWWA C606 for grooved-end connections.
- D. NSF Compliance: [NSF 61] [and] [NSF 372] for valves in potable-water service.
- E. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- F. Valve Sizes: Same as upstream piping unless otherwise indicated.
- G. Valve Actuator Types:
1. Gear Actuator: For valves NPS 8 (DN 200) and larger.
 2. Handlever: For valves NPS 6 (DN 150) and smaller.
 3. Chainwheel: Device for attachment to gear, handlever, or stem; of size and with chain for mounting height, according to "Valve Installation" Article.
- H. Valves in Insulated Piping: With 2-inch (50-mm) stem extensions.

2.2 IRON, SINGLE-FLANGE BUTTERFLY VALVES

- A. Iron, Single-Flange Butterfly Valves with Aluminum-Bronze Disc:
1. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc.; [LD141, NPS 2 - 24 (DN 50 - DN 600)] [LD145, NPS 2 - 12 (DN 50 - DN 300)] [LC149, NPS 2 - 12 (DN 50 - DN 300)] or a comparable product by one of the following:
 - a. Stockham; Crane Energy Flow Solutions.
 - b. WATTS.
 - c. <Insert manufacturer's name>.

2. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating for Valves **NPS 2 (DN 50) to NPS 12 (DN 300): 200 psig (1380 kPa)**.
 - c. CWP Rating for Valves **NPS 14 (DN 350) to NPS 24 (DN 600): 150 psig (1030 kPa)**.
 - d. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
 - e. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
 - f. Seat: **[EPDM] [NBR]**.
 - g. Stem: One- or two-piece stainless steel.
 - h. Disc: Aluminum bronze.

B. Iron, Single-Flange Butterfly Valves with Ductile-Iron Disc:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc.; [**LD141 NPS 2 to NPS 24 (DN 50 to DN 600)**] [**LD145 NPS 2 to NPS 12 (DN 50 to DN 300)**] or a comparable product by one of the following:
 - a. Stockham; Crane Energy Flow Solutions.
 - b. WATTS.
 - c. **<Insert manufacturer's name>**.

2. Description:

- a. Standard: MSS SP-67, Type I.
- b. CWP Rating for Valves **NPS 2 (DN 50) to NPS 12 (DN 300): 200 psig (1380 kPa)**.
- c. CWP Rating for Valves **NPS 14 (DN 350) to NPS 24 (DN 600): 150 psig (1030 kPa)**.
- d. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
- e. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
- f. Seat: **[EPDM] [NBR]**.
- g. Stem: One- or two-piece stainless steel.
- h. Disc: Nickel-plated[**or -coated**] ductile iron.

C. Iron, Single-Flange Butterfly Valves with Stainless-Steel Disc:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc.; [**LD141, NPS 2 to NPS 24 (DN 50 to DN 600)**] [**LD145 NPS 2 to NPS 12 (DN 50 to DN 300)**] or a comparable product by one of the following:
 - a. Stockham; Crane Energy Flow Solutions.
 - b. WATTS.
 - c. **<Insert manufacturer's name>**.

2. Description:

- a. Standard: MSS SP-67, Type I.
- b. CWP Rating for Valves **NPS 2 (DN 50) to NPS 12 (DN 300): 200 psig (1380 kPa)**.

- c. CWP Rating for Valves **NPS 14 (DN 350) to NPS 24 (DN 600): 150 psig (1030 kPa)**.
- d. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
- e. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
- f. Seat: **[EPDM] [NBR]**.
- g. Stem: One- or two-piece stainless steel.
- h. Disc: Stainless steel.

2.3 DUCTILE IRON WAFER (Flangeless) BUTTERFLY VALVES

A. Ductile Iron, Wafer (flangeless) Butterfly Valves with Aluminum-Bronze Disc:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc.; **[WD141, NPS 2 to NPS 12 (DN 50 to DN 300)] [WD145, NPS 2 to NPS 12 (DN 50 to DN 300)]**, or a comparable product by one of the following:
 - a. Stockham; Crane Energy Flow Solutions.
 - b. WATTS.
 - c. **<Insert manufacturer's name>**.
2. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating for Valves **NPS 2 (DN 50) to NPS 12 (DN 300): 200 psig (1380 kPa)**.
 - c. Body Material: ASTM A 536, ductile iron.
 - d. Seat: **[EPDM] [NBR]**.
 - e. Stem: One- or two-piece stainless steel.
 - f. Disc: Aluminum bronze.

B. Ductile Iron, Wafer (flangeless) Butterfly Valves with Ductile-Iron Disc:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc.; **[WD141, NPS 2 to NPS 12 (DN 50 to DN 300)] [WD145, NPS 2 to NPS 12 (DN 50 to DN 300)]** or a comparable product by one of the following:
 - a. Stockham; Crane Energy Flow Solutions.
 - b. WATTS.
 - c. **<Insert manufacturer's name>**.
2. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating for Valves **NPS 2 (DN 50) to NPS 12 (DN 300): 200 psig (1380 kPa)**.
 - c. Body Material: ASTM A 536, ductile iron.
 - d. Seat: **[EPDM] [NBR]**.
 - e. Stem: One- or two-piece stainless steel.
 - f. Disc: Ductile Iron.

C. Ductile Iron, Wafer (flangeless) Butterfly Valves with Stainless Steel Disc:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc.; [WD141, NPS 2 to NPS 12 (DN 50 to DN 300)] [WD145 NPS 2 to NPS 12 (DN 50 to DN 300)], or a comparable product by one of the following:
 - a. Stockham; Crane Energy Flow Solutions.
 - b. WATTS.
 - c. <Insert manufacturer's name>.
2. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating for Valves NPS 2 (DN 50) to NPS 12 (DN 300): 200 psig (1380 kPa).
 - c. Body Material: ASTM A 536, ductile iron.
 - d. Seat: [EPDM] [NBR].
 - e. Stem: One- or two-piece stainless steel.
 - f. Disc: Stainless Steel.

2.4 DUCTILE-IRON, GROOVED-END BUTTERFLY VALVES

A. Ductile Iron, Grooved-End Butterfly Valves, 175 CWP:

1. Basis-of-Design Product: Subject to compliance with requirements, provide products by Apollo-Shurjoint Piping Products USA Inc.; [SJ-300N-L] [SJ-300N-W], or a comparable product by one of the following:
 - a. Kennedy Valve Company; a division of McWane, Inc.
 - b. Tyco Fire Products LP.
 - c. Victaulic Company.
 - d. Zurn Industries, LLC.
 - e. <Insert manufacturer's name>.
2. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating: 175 psig (1200 kPa).
 - c. Body Material: Coated, ductile iron.
 - d. Stem: Two-piece stainless steel.
 - e. Disc: Coated, ductile iron.
 - f. Seal: EPDM.

B. Ductile Iron, Grooved-End Butterfly Valves, 300 CWP:

1. Basis-of-Design Product: Subject to compliance with requirements, provide products by Apollo-Shurjoint Piping Products USA Inc.; [SJ-300N-L] [SJ-300N-W], or a comparable product by one of the following:
 - a. Anvil International.
 - b. Kennedy Valve Company; a division of McWane, Inc.

- c. Mueller Steam Specialty; A WATTS Brand.
 - d. NIBCO INC.
 - e. Tyco Fire Products LP.
 - f. Victaulic Company.
 - g. <Insert manufacturer's name>.
2. Description:
- a. Standard: MSS SP-67, Type I.
 - b. CWP Rating, **NPS 8 (DN 200)** and Smaller: **300 psig (2070 kPa)**.
 - c. CWP Rating, **NPS 10 (DN 250)** and Larger: **200 psig (1380 kPa)**.
 - d. Body Material: Coated, ductile iron.
 - e. Stem: Two-piece stainless steel.
 - f. Disc: Coated, ductile iron.
 - g. Seal: [EPDM] [NBR].

2.5 CHAINWHEELS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide Apollo, Conbraco Industries, Inc. chainwheels, or comparable products by one of the following:
- 1. Babbitt Steam Specialty Co.
 - 2. Roto Hammer Industries.
 - 3. Trumbull Industries.
 - 4. <Insert manufacturer's name>.
- B. Description: Valve actuation assembly with sprocket rim, chain guides, chain[, **and attachment brackets for mounting chainwheels directly to handwheels**].
- 1. Sprocket Rim with Chain Guides: [**Ductile iron**] [**Ductile or cast iron**] [**Cast iron**] [**Aluminum**] [**Bronze**], of type and size required for valve. [**Include zinc or epoxy coating.**]
 - 2. Chain: [**Hot-dip, galvanized steel**] [**Brass**] [**Stainless steel**], of size required to fit sprocket rim.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.

- C. Examine mating flange faces for damage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- D. Do not attempt to repair defective valves; replace with new valves.

3.2 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install chainwheels on operators for butterfly valves [**NPS 4 (DN 100)**] <Insert size> and larger and more than [**96 inches (2400 mm)**] <Insert dimension> above floor. Extend chains to [**60 inches (1520 mm)**] <Insert dimension> above finished floor.
- F. Install valve tags. Comply with requirements in Section 220553 "Identification for Plumbing Piping and Equipment" for valve tags and schedules.

3.3 ADJUSTING

- A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

3.4 LOW-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (**150 PSIG (1035 kPa)** OR LESS)

- A. Iron, Single-Flange or Wafer Butterfly Valves: 200 CWP, NBR seat, [**aluminum-bronze**] [**ductile-iron**] [**stainless-steel**] disc.
- B. Ductile-Iron, Grooved-End Butterfly Valves: [**175**] [**300**] CWP.

3.5 HIGH-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (**150 TO 200 PSIG (1035 TO 1380 kPa)**)

- A. Iron, Single-Flange or Wafer Butterfly Valves: 200 CWP, NBR seat, [**aluminum-bronze**] [**ductile-iron**] [**stainless-steel**] disc.
- B. Ductile-Iron, Grooved-End Butterfly Valves: [**175**] [**300**] CWP.

3.6 DOMESTIC HOT- AND COLD-WATER VALVE SCHEDULE

- A. Iron, Single-Flange or Wafer Butterfly Valves: 200 CWP, [EPDM] [NBR] seat, [aluminum-bronze] [ductile-iron] [stainless-steel] disc.
- B. Ductile-Iron, Grooved-End Butterfly Valves: [175] [300] CWP.

END OF SECTION 220523.13